## INSPECTION CHECKLIST RESIDENTIAL SINGLE FAMILY DWELLING

SITE .	ADDRESS:				
ELEC	CTRICAL ITEMS				
	ELECTRICAL SERVICE CONNECTIONS:	PASS		FAIL	
	SERVICE GROUND TO WATER PIPE:	PASS		FAIL	
	MINIMUM 100 amp SERVICE:	PASS		FAIL	
	CONDITION OF ELECTRICAL SERVICE CAB	BLE	PASS		FAIL
	TWO RECEPTACLES PER ROOM:		YES		NO
	UNUSED OPENINGS IN PANEL BOX CLOSEI	D:	YES		NO
	CLOSET LIGHT FIXTURE STATUS:		PASS		FAIL
	PROPER RECEPTACLE in BATHROOM: (Fixture receptacles eliminated) YES			nted) YES	

ELEC	TRICAL ITEMS (continued)			
	KITCHEN GFIC RECEPTACLES:	YES	NO	
<u> </u>	VISIBLE ELECTRICAL VIOLATIONS:	YES	NO	
FIF	RE SAFETY			
	SMOKE DETECTORS: (on all levels including baser	ment and each sleepin	g area) YES	NO
	SMOKE DETECTORS (battery back up, interconnection)	cted if constructed af	ter 1993) YES N	NO NA
	FIREWALLS BETWEEN UNITS: (where applicable)	ble) YES	NO NA	
	FIREWALL BETWEEN GARAGE and LIVII	NG AREA: 1/2	" 5/8" PASS I	FAIL NA
	SOLID CORE: (not raised panel or door with glass; gara	age & living area) PA	ASS FAIL	NA
	OPERATIONAL WINDOWS IN SLEEPING A	AREAS:	PASS	FAIL

VE	NTING/MECHANICAL				
	DRYER VENTING: (to exterior or other approved method)	PASS	FAI	L NA	
	CHIMNEY VENTING: (for High Efficiency Heaters)	PASS	FAIL		
	MULTI FLUE USAGE: YES	NO	PASS	FAIL	_
	OIL BURNER SHUT OFF SWITCH: (at top of stairs	s or outside hea	ater room) PA	ASS FAIL	NA
1:1 <b>]</b>	HOT WATER HEATER: (Temperature & Pressure Valve pipe	ed within 6' of fl	oor)	PASS	FAIL
	EXHAUST FAN/OPERATION WINDOW: (In I	Bathroom)	P	PASSFAIL	
	MISCELLANEOUS				
	HANDRAILS ON STAIRS: (if two steps or more)	PASS	FAIL	NA	
	BARRIERS ON OPEN STAIRWAYS: PASS	S F	AIL	NA	
	STRUCTURAL DAMAGE: YES	NO			

	MISCELLANEOUS (continue)					
	CRACKED/BROKEN WINDOWS:	YES	NO			
	CONCRETE FLOOR: (in basement)	,	YES	NO		
	INTERIOR WASATE/DEBRIS/SANIT	ATION CO	NDITION	S: PASS	FAIL	
	EXTERIOR					
	SWIMMING POOL: (secured proper	ly) PASS	FAIL	N	A	
	PROPERTY ADDRESS PROPERLY	DISPLAY	ED: (minim	um 4" H Nu	mbers) PASS No	0
	REMOVAL/ABANDONMENT of CISTI	ERN/OUTH	OUSE:	YES	NO	
	EXTERIOR WASTE/DEBRIS/SANITA	ARY COND	TIONS:	PASS FA	AIL	
	SIDEWALS/CURB NO MORE THAN 2'	" TOE TRIP				
	ALL EXTERIOR WOODS AND MATER DING FOR PROTECTION AGAINST ELI			RLY COVI FAIL	ERED WITH PA	AINT,
ВС	CO Signature					
Da	te					